

**REGIONAL WATER TESTING LAB, HOSHIARPUR**

Government ITI, Jalandhar Road, Hoshiarpur  
rwtlhsp@gmail.com

To,

Kendriya Vidyalaya No.2 AFS Adampur  
Air Force Station, Adampur, Distt. Jalandhar

No.: RWTLHSP/2223/00264 Dated : 11/10/2022

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. F.59/1646/KV-2/2022-23/78 Dated: 03/10/2022

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 03/10/2022. It is request to fill the attached feedback form and send it back to Regional Water Testing Lab, Hoshiarpur

D/A : 1 Test Report



**Authorized Signatory**  
**For, Regional Water Testing Lab, Hoshiarpur**

## REGIONAL WATER TESTING LAB, HOSHIARPUR

Government ITI, Jalandhar Road, Hoshiarpur  
rwtlhsp@gmail.com



### TEST REPORT

Name & Address of Customer : <b>Kendriya Vidyalaya No.2 AFS Adampur</b> <b>Air Force Station, Adampur, Distt. Jalandhar</b>	Customer Reference No.	No : F.59/1646/KV-2/2022-23/78 Dated : <b>03/10/2022</b>
	Sample Submitted by	<b>Shri Paramjit Ram</b>
	Date of Sample Receipt	<b>03/10/2022</b>
	Analysis Starting Date	<b>06/10/2022</b>
	Analysis completion Date	<b>08/10/2022</b>


Discipline : <b>Chemical Testing</b>		Group: <b>Water</b>	
Test Report No.:	<b>RWTLHSP/2223/00264</b>	Date of Issue :	<b>11/10/2022</b>
Registration no.:	<b>RWTLHSP/REG2223/00707</b>	Condition of Sample :	<b>Unsealed</b>
Source :	<b>RO</b>	Quantity/Type of Bottle:	<b>1000 ml / Amber Colored Glass Bottle</b>
Scheme :	<b>NA</b>	Location/Depth :	<b>Air Force Station, Adampur, Distt. Jalandhar / NA</b>
Village :	<b>NA</b>	Habitation :	<b>NA</b>
Block:	<b>Adampur</b>	District :	<b>Jalandhar</b>
Latitude :	<b>NA</b>	Longitude:	<b>NA</b>

Sample Type: **Water**

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	8.43	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-1993 ) Electrometric Method
2	Colour	3	5	15	Hazen	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Disagreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Disagreeable	--	IS 3025 (Part 8 – 1984) (RA 2017)
5	TDS	299	500	2000	mg/l	IS 3025 (Part 16-1984) Gravimetric Method
6	Turbidity	<b>2.24</b>	1	5	NTU	IS 3025 (Part 10-1984) Nephelometric Method
7	Alkalinity	<b>234</b>	200	600	mg/l	IS 3025 (Part 23-1986) Indicator Method
8	Hardness	<b>244.44</b>	200	600	mg/l	IS 3025 (Part 21- 2019) EDTA Method
9	Calcium	69.97	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
10	Magnesium	16.97	30	100	mg/l	APHA (23rd Ed.2017) Method: 3500-Mg+2 B By Calculation Method
11	Chloride	26.60	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. This report is referring only to the tested sample and for applicable parameter.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed)
5. \* Value not available or test not performed for this parameter.

  
**Mr. Jivesh Kumar**  
**Quality Manager**  
**Authorized Signatory**  
**For, Regional Water Testing Lab,**  
**Hoshiarpur**

**REGIONAL WATER TESTING LAB, HOSHIARPUR**

Government ITI, Jalandhar Road, Hoshiarpur  
rwtlhsp@gmail.com



----- End of the Test Report -----

## REGIONAL WATER TESTING LAB, HOSHIARPUR

Government ITI, Jalandhar Road, Hoshiarpur  
rwlhsp@gmail.com

### TEST REPORT

Name & Address of Customer : Kendriya Vidyalaya No.2 AFS Adampur Air Force Station, Adampur, Distt. Jalandhar	Customer Reference No.	No : F.59/1646/KV-2/2022-23/78 Dated : 03/10/2022
	Sample Submitted by	Shri Paramjit Ram
	Date of Sample Receipt	03/10/2022
	Analysis Starting Date	06/10/2022
	Analysis completion Date	08/10/2022

Discipline : Bacteriological Testing	Group: Water
Test Report No.: RWTLHSP/2223/00264	Date of Issue : 11/10/2022
Registration no.: RWTLHSP/REG2223/00707	Condition of Sample : Unsealed
Source : RO	Quantity/Type of Bottle: 1000 ml / Amber Colored Glass Bottle
Scheme : NA	Location/Depth : Air Force Station, Adampur, Distt. Jalandhar / NA
Village : NA	Habitation : NA
Block: Adampur	District : Jalandhar
Latitude : NA	Longitude: NA
Sample Type: Water	

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	Total Coliform	ND	Shall not be detectable in any 100 ml sample	No relaxation	MPN/100 ml.	IS-1622 MPN Method
2	E-Coli	ND	Shall not be detectable in any 100 ml sample	No relaxation	MPN/100 ml.	IS-1622 MPN Method

This Report is issued under the following terms & Condition :

1. This report is referring only to the tested sample and for applicable parameter.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed)
5. \* Value not available or test not performed for this parameter.



Mr. Jivesh Kumar  
Quality Manager  
Authorized Signatory  
For, Regional Water Testing Lab,  
Hoshiarpur

----- End of the Test Report -----